Exhibit JJ-2

```
1
 2
 3
 4
 5
 6
7
 8
 9
10
11
12
     07-13-21 - 0907 - NDCC Operator #1 - Hydro
13
     Operator #1
14
15
16
17
18
19
20
21
22
23
24
25
                                                   Page 1
```

```
1
               HYDRO OPERATOR #1:
     at Rock Creek.
2
3
               NDCC OPERATOR #1: Hey.
               HYDRO OPERATOR #1: So there is trouble
4
5
     on the Bucks 1101. It seems to be energized at
     the sub there by Bucks Powerhouse. But somewhere
6
    from there down to Cresta Dam and the tunnel on
    Highway 70 must be where the trouble is, because
8
    we do not have station service at Cresta Dam and
9
10
     all the lights are out inside the Elephant Butte
11
    Tunnel.
12
               NDCC OPERATOR #1: Hmm. That's not
13
    good.
14
               HYDRO OPERATOR #1: No.
15
               NDCC OPERATOR #1: Bucks Creek -- yeah,
16
    because everything looked normal on the breaker,
17
    but...
               HYDRO OPERATOR #1: I mean, it hasn't
18
    been windy here, you know. So I don't know what
19
    could've caused it. But yeah, my rover down
20
21
     there at the sub says everything looks good in
22
    the sub. There's no blown fuses or anything and
23
     it's supplying station service to Bucks
24
    Powerhouse. So from the sub to the dam and the
25
    tunnel there's some trouble.
```

Case 3:14-cr-00175-WHA Document 1474-3 Filed 09/17/21 Page 4 of 5

```
1
              NDCC OPERATOR #1: Gotcha. Let me see
    the dam. Okay. I wonder if... Let me see
2
    where... Buck Creek, Cresta Damn.
3
    (indiscernible) All right. So what, is this
4
5
    Cresta Dam? Is that where you don't have your
    station service?
6
7
              HYDRO OPERATOR #1: That's correct.
              NDCC OPERATOR #1: Okay. Gotcha. Did
8
9
    your rover happen to look at the fuses there?
    Looks like we've got two sets of fuses, 805 and
10
11
    then also --
              HYDRO OPERATOR #1: I don't -- he
12
13
    didn't say if he looked at them or not.
              NDCC OPERATOR #1: Okay. Gotcha.
14
    Either way, I will get a troubleman heading that
15
16
    way.
17
              HYDRO OPERATOR #1: Okay. Thank you
18
    very much.
19
              NDCC OPERATOR #1: All right. Yep.
20
    Not a problem.
21
              HYDRO OPERATOR #1: Bye.
22
23
24
25
                                              Page 3
```

1	CERTIFICATION
2	
3	I, Sonya Ledanski Hyde, certify that the
4	foregoing transcript is a true and accurate
5	record of the proceedings.
6	Date: September 15, 2021
7	
8	
9	
10	_ Saugh Itely
11	Sonya Ledanski Hyde
12	
13	
14	
15	
16	
17	
18	
19	
2 0	
21	
23	
24	
25	
- 0	
	Page 4